

TEST CERTIFICATE

BT-24-09-24-01

- Product:** Chambroad Timber
(Biomass Modified Recombinant Poplar)
- Supplier:** Shandong Chambroad Timber Material Co., Ltd.
Economic Development Zone, Boxing County, Binzhou City,
Shandong Province, China
- Order:** Mold resistance according to DIN EN ISO 846:2020, method A
- Test report:** 2224031-1/A1 dated 24 September 2024
- Test details:** Five test specimen replicates were tested with a mixed spore suspension of *Aspergillus niger*, *Talaromyces pinophilus*, *Paecilomyces variotii*, *Trichoderma viride* and *Chaetomium globosum* without the addition of nutrients over an incubation period of 4 weeks. No artificial ageing or weathering was carried out before the fungal test.
- Test results:** The non-weathered material was resistant to mold (class "0") and did not provide a nutrient source for mold fungi.

Place, date of issue: Dresden, 24 September 2024



Head of laboratory



Engineer in charge